

ROOM DATA SHEET				
Sister's Office		Date	Oct 2018	 Andrew Associates
		Room no.	R22	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1		Waste Bin	1	
2		Secretary type Chair	1	
3		Patient Chairs	3	
4		1500 x 800 desk or Bench	1	Design specific

BUILDING		Comment/ Quantity
Ref.		
B1	Walls	Low Odour Eggshell
B2	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber
B3	Doors (HBN 00-04)	Single Door
B4	Signage (HTM 65)	
B5		Room Number sign
B6	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles
B7	Noise (HTM (08-01)	Privacy
		■ 40 (NR)
SERVICES		
Water (HTM 04-01)		
		N/R
Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr
		■ environment to be 18-28°C
Electrical (CIBSE design guide)		
E1	13A Double sockets E1 - Utility E1 - Desk E1 – Wall	Non-Essential Supply Low Level
		2 No 2 No on dado trunking
Gases (HTM 02-01)		
		N/A
Lighting (EN12464-1)		
L1	General room lighting	
L2	Emergency Lighting	Integral
		Em = 300lx
Communication (HTM 08-03)		
C1	Data Outlet	
C2	Fire Detection	
		1 No
		1 No Smoke