

ROOM DATA SHEET				
4 Bed Bay (Different Pod Options available see Sanitary Pods R2)		Date	Sept 2018	
		Room no.	R1	
		Rev. no	v1	
This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms BIMhealth take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	1	Wash hand basin on IPS	1	- Complete with lever action sequential mixer bib tap - Basin to be clinical, no plug, no overflow, and back outlet, no tap holes
2	2	Paper Towel Dispenser (HBN 00-09)	1	
3	2	Soap Dispenser (HBN 00-09)	2	No soap dishes in healthcare environment
4	2	Hand Cream Dispenser (HBN 00-09)		
5	2	Hand Gel Dispenser (HBN 00-09)	1	- Point of ward entry - Each bed (Design Specific)
6	2	PPE Dispenser	1	
7	3	Sack holder (Clinical)	1	
8	3	Sack holder (domestic)	1	
9	3	Automatic medical bed	4	Low positioned 13amp power socket.
10	3	Therapist Stool		N/R
11	3	Trolley		N/R
12	3	Suction Flowmeter	4	
13	3	Oxygen Flowmeter	4	
14	3	Air Flowmeter	4	
15	3	Drip Stand	4	As Required
16	3	IV pump	4	As Required
17	1	Observation Nurse Base	1	Design Specific
18	3	Patient Chair	4	Design Specific
19	3	Visitor's Chair	4	Design Specific
20	3	Bedside Locker	4	Design Specific
21	3	Over Bed Tables	4	Design Specific
22	1	Bed Bay Curtains/Track (Anti-ligature)	4	Design Specific
23	1	Bedhead Services	4	Delivered by specialist medical trunking

BUILDING			Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	Microban protection as required
B2	Splashbacks/IPS		Whiterock or Similar as required
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	Design Specific
B4	Doors (HBN 00-04)		Design Specific
B5	Signage (HTM 65)		Room ID - Design Specific
B6		Room Number signage	
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	
B8	Noise (HTM (08-01)	Privacy	40 (NR)
SERVICES			
Water (HTM 04-01)			
W1	Hot water		1
W2	Cold water		1 Non potable -
Ventilation, Heating, Cooling (HTM 03-01)			
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	Environment to be 18-28°C
			Design Specific
Electrical (CIBSE design guide) Design Specific			
E1	13A Double socket	Essential Supply	6 No per medical trunking
E2	13A Single socket	Non-Essential supply	1No low level per bed
E3	13A Wall socket	Non-Essential supply	Cleaner sockets as required
E4	Dado Trunking above W/T	Non-Essential supply	Observation Nurse Base - Min 2 x twin sockets + Data as req'd
F1	Fire Detection & Alarms		Design Specific
Gases (HTM 02-01)			
G1	Oxygen		4
G2	Suction		4
G3	Air		4
Lighting (EN12464-1)			
L1	General room lighting	LED Modular	Em = 300lx
L2	Emergency Lighting	Integral	
L3	Examination Lamp	Luxo inspection lamps	4
L4	Overbed Lighting	Switched @ Trunking & NC handset	4 4
Communication (HTM 08-03)			
C1	Data Outlet		Design Specific
C2	Fire Detection		1 No Smoke
C3	Nurse Call System		Design Specific