

ROOM DATA SHEET				
Office		Date	Sept 2018	
		Room no.	R43-5	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. BIMhealth take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1		Design Specific		

	BUILDING		Comment/ Quantity
Ref.			
B1	Design Specific		
	SERVICES		
	Water (HTM 04-01)		
W1	Design Specific		
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	Environment to be 18-28°C
	Design Specific		
	Electrical (CIBSE esign Specificdesign guide) Design Specific		
E1	Design Specific	Essential Supply	
F1	Fire Detection & Alarms		Design Specific
	Gases (HTM 02-01)		
G1	Design Specific		
	Lighting (EN12464-1)		
L1	Design Specific		
	Communication (HTM 08-03)		
C1	Design Specific		