

ROOM DATA SHEET				
Beverage Kitchen		Date	Sept 2018	 Andrew Associates
		Room no.	R16	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	1	Wash hand basin on IPS	1	- Complete with lever action sequential mixer bib tap - Basin to be clinical, no plug, no overflow, and back outlet, no tap holes
2		Paper Towel Dispenser (HBN 00-09)	1	
3		Soap Dispenser (HBN 00-09)	1	No soap dishes in healthcare environment
4		Hand Cream Dispenser (HBN 00-09)	1	
5		Hand Gel Dispenser (HBN 00-09)	1	
6		S/S sink/drain	1	Domestic Hot & Cold water supplies (NO TMV)
8		Sack holder (domestic) Sack Holder (Clinical)	1 1	
9		Drinks Trolley	1	Allow for storage floor space if required
10		Heater Cabinet	1	Allow for storage floor space if item required. Also, electrical connection
11		Base Unit with w/top		Design Specific
12		Wall Cup'ds		Design Specific
13		Space for fridge under w/top	1	

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	
B2	Splashback		Whiterock or Similar
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	
B4	Doors (HBN 00-04)	Single Door	With Deadlock or digital lock
B5	Signage (HTM 65)		As Required
B6		Room Number sign	
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	
B8	Noise (HTM (08-01)	Privacy	40 (NR)
	SERVICES		
	Water (HTM 04-01)		
W1	Hot water		1
W2	Cold water		1 potable -
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Double socket	Non-Essential Supply	Design Specific
E2	Usually dedicated supply.	Water Boiler (over drainer)	Installations in accordance with Manufacturer's instructions.
	Gases (HTM 02-01)		
G1	Oxygen		N/R
G2	Suction		N/R
	Lighting (EN12464-1)		
L1	General room lighting		Em = 300lx
L2	Emergency Lighting	Integral	
L3	Heater Cabinet	If Required	Design Specific
	Communication (HTM 08-03)		
C1	Data Outlet		N/R
C2	Fire Detection		1 No Smoke (Heat Detector)