

ROOM DATA SHEET				
MRI Suite Control Room		Date	Sept 2018	
		Room no.	R42-1	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1		Desk benching 750mm high 38mm thick mdf laminated Anti-Bacterial Protected		Qty as required
2		Console desk surfaces Anti-Bacterial Protected	1	
3		Console chair Anti-Bacterial Fabric.	1	As required
4		Viewing window	1	

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Splashback		N/A
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B4	Doors (HBN 00-04)	Single Door	■ With Deadlock or digital lock
B5	Signage (HTM 65)		■
B6		Room Number sign	■
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B8	Noise (HTM (08-01)	Privacy	■ 40 (NR)
	SERVICES		
	Water (HTM 04-01)		
W1	Hot water		N/A
W2	Cold water		N/A
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	■ environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Double socket	Essential Supply	6 No on dado trunking or as req'd.
E2	Macerator Supply	20amp single phase	N/A
	Gases (HTM 02-01)		
G1	Oxygen		N/A
G2	Suction		N/A
	Lighting (EN12464-1)		
L1	General room lighting		Em = 300lx
L2	Emergency Lighting	Integral	
L3	Examination Lamp		N/A
	Communication (HTM 08-03)		
C1	Data Outlet		As Required
C2	Fire Detection		1no min
C3	Emergency run-down push button	Located near console desk	1no