

ROOM DATA SHEET				
Nurse Station		Date	Sept 2018	 Andrew Associates
		Room no.	R26	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	3	Notes Trolley	2	As Required
2	3	Office Chair	3	As Required
3	1	Custom Made desk	1	DDA St'd - Design Specific
4	1	Rear Base cup'ds + W/Top		900 high – Design Specific
5	1	Rear Wall Cup'ds		Design Specific

BUILDING			Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Splashback	Above rear w/top	■ Whiterock or Similar
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B4	Signage (HTM 65)		■
B5		Room Number sign	■
B6	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B7	Noise (HTM (08-01)	Privacy	■ 40 (NR)
SERVICES			
	Water (HTM 04-01)		
W1	Hot water		1
W2	Cold water		1 Non potable -
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	■ environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Double socket E1(U) Utility E1(A) Desk	Non Essential Supply	2 No above rear w/top 6 No on dado trunking min 1 No
E2	Nurse Call Panel		Located Locally
	Gases (HTM 02-01)		
G1	Oxygen		N/A
G2	Suction		N/A
	Lighting (EN12464-1)		
L1	General room lighting		Em = 300lx
L2	Emergency Lighting	Integral	
	Communication (HTM 08-03)		
C1	Data Outlet		3 No min suggested
C2	Fire Detection		1 No Smoke