

ROOM DATA SHEET				
Orthodontist		Date	Sept 2018	
		Room no.	R35	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	1	Wash hand basin	1	- Complete with lever action sequential mixer bib tap - Basin to be clinical, no plug, no overflow, and back outlet, no tap holes
2		Paper Towel Dispenser (HBN 00-09)	1	
3		Soap Dispenser (HBN 00-09)	1	No soap dishes in healthcare environment
4		Hand Cream Dispenser (HBN 00-09)	1	
5		Hand Gel Dispenser (HBN 00-09)	1	
6		PPE Dispenser	1	
8		Waste Bin (clinical)	1	
9		Clinical staff Stool	2	
10		Mobile Cart	1	
11		Base Units w/top	1	Design Specific
12		Sink with cabinet	1	
13		Orthodontist Chair	1	Automation facility
14		Spittoon and services floor box	1	Design Specific
15		Suction Motor	1	Design Specific
16		Suction Cabinet	1	Design Specific
17		Cabinet Mounted Manifold	1	Design Specific

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Splashback		■ Whiterock or Similar
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B4	Doors (HBN 00-04)	Single Door	■ With Deadlock or digital lock
B5	Signage (HTM 65)		■
B6		Room Number sign	■
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B8	Noise (HTM (08-01)	Privacy	■ 40 (NR)
	SERVICES		
	Water (HTM 04-01)		
W1	Hot water		1
W2	Cold water		1 Non potable -
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	■ environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Twin sockets	Non-Essential Supply	Design Specific
E2	Suction Motor	Essential Supply	Design Specific
E3	Orthodontist Chair	Essential Supply	Design Specific
	Gases (HTM 02-01)		
G1	Oxygen		Design Specific
G2	Suction		Design Specific
G3	Entonox Oxide		Design Specific
	Lighting (EN12464-1)		
L1	General room lighting		Em = 300lx
L2	Emergency Lighting	Integral	
L3	Examination Lamp		Em = 1000lx
	Communication (HTM 08-03)		
C1	Data Outlet		Design Specific
C2	Fire Detection		1 No Smoke