

ROOM DATA SHEET				
Prep Room		Date	Sept 2018	
		Room no.	R20	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	1	Wash hand basin on IPS	1	- Complete with lever action sequential mixer bib tap - Basin to be clinical, no plug, no overflow, and back outlet, no tap holes
2		Paper Towel Dispenser (HBN 00-09)	1	
3		Soap Dispenser (HBN 00-09)	1	No soap dishes in healthcare environment
4		PPE dispenser (HBN 00-09)	1	
5		Hand Gel Dispenser (HBN 00-09)	1	
7		Sack holder (Clinical)	1	
8		Sack holder (domestic)	1	
9		Wall shelving		Design Specific
10		w/top c/w base units and wall cup'ds		Design Specific
11		Storage Units		Design Specific
12		Drugs Fridge	1	
13		Drugs Cabinet	1	

BUILDING			Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Splashback		■ Whiterock or Similar
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B4	Doors (HBN 00-04)	Single Door	■ With Deadlock or digital lock
B5	Signage (HTM 65)		■
B6		Room Number sign	■
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B8	Noise (HTM (08-01)	Privacy	■ 40 (NR)
SERVICES			
Water (HTM 04-01)			
W1	Hot water		1
W2	Cold water		1 Non potable -
Ventilation, Heating, Cooling (HTM 03-01)			
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	■ environment to be 18-28°C
Electrical (CIBSE design guide)			
E1	13A Double socket E1(U) Utility E1(A) Desk E1(C) Couch	Non Essential Supply	2 No 2 No on dado trunking 1 No
E2	Macerator Supply	3 Phase	
Gases (HTM 02-01)			
G1	Oxygen		1
G2	Suction		1
Lighting (EN12464-1)			
L1	General room lighting		Em = 300lx
L2	Emergency Lighting	Integral	
L3	Examination Lamp		Em = 1000lx
Communication (HTM 08-03)			
C1	Data Outlet		2 No
C2	Fire Detection		1 No Smoke