

[illegible]

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Splashback		
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B4	Doors (HBN 00-04)	Single Door	■ With Deadlock or digital lock
B5	Signage (HTM 65)		■
B6		Room Number sign	■
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B8	Noise (HTM (08-01)	Privacy	■ 40 (NR)
	Induction loop see above		
	SERVICES		
	Water (HTM 04-01)		
W1	Hot water		-
W2	Cold water		-
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation		■ environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Double socket E1(A) Admin E2(U) Utility	Dado trunking with cable management	3 No 1 No
E2	13A FCU Nurse Call		1
E3	13A FCU Fire Alarm Panel		1
E4	13A FCU Induction Loop		1
E5	13A FCU Medical Gas		TBC
	Gases (HTM 02-01)		
	AVSU no outlets	Not required for room	1
	Lighting (EN12464-1)		
L1	General room lighting		Em = 500lx
	Communication (HTM 08-03)		
C1	Fire Detection		1 No Smoke
C2	Data		3 No
C3	Nurse call alarm panel		1 No
C4	Fire alarm Repeater Panel		1 No