

ROOM DATA SHEET				
Plaster Room		Date	Aug2018	 Andrew Associates
		Room no.	R32	
		Rev. no	V1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	1	Stainless Steel Plaster Sink on IPS	1	- Complete with Hot and Cold lever action taps (non-thermostatic) - Ensure adequate access within panel system
2		Wash hand basin on IPS	1	- Complete with lever action sequential mixer bib tap - Basin to be clinical, no plug, no overflow, and back outlet, no tap holes
3		Cubicle Tracking	1	Anti-Ligature
4		Paper Towel Dispenser	1	
5		Soap Dispenser	2	
6		Hand Cream Dispenser	1	
7		Alcohol Gel Dispenser	1	
8		Glove/Apron dispenser	1	
	3			
9		Treatment Couch complete with paper roll	1	
10		Upright Chair	1	
11		Therapist Stool	1	
12		Gratnells Trolley	1	
13		Plaster Trolley	1	
14		Sack holder (Clinical)	1	
15		Sack holder (domestic)	1	
16		Drip Stand	1	
17		IV Pump	1	
18		Clinical Workstation	1	
19		Stackable chairs	2	
	4			
20		Disposable Curtains	1	
21		clock	1	
22		Computer	1	
23		Whiteboard	1	

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Splashback		■ Whiterock or Similar
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B4	Doors (HBN 00-04)	Single Door	■ With Deadlock or digital lock
B5	Signage (HTM 65)		■ with occupancy indicator
B6		Room Number sign	■
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B8	Noise (HTM (08-01)	Privacy	■ 40 (NR)
	SERVICES		
	Water (HTM 04-01)		
W1	Hot water		2
W2	Cold water		2 Non potable
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	3 (Pa) 7 AC/Hr	■ environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Double socket outlets	Non-Essential	Design Specific
	Gases (HTM 02-01)		
		Not required for room	
	Lighting (EN12464-1)		
L1	General room lighting		Em = 500lx
L2	Emergency Lighting	Integral	
	Communication (HTM 08-03)		
C1	Fire Detection		1 No Smoke
	Data		1 No
	Telephone		1 No or VOIP
	Nurse call		Panic alarm
	Sounder Beacon		1 No