

ROOM DATA SHEET				
Office		Date	Oct 2018	 Andrew Associates
		Room no.	R27	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1		Waste Bin	1	
2		Secretary type Chair	3	
3		Bench desk 3000x800x40mm	3	Design specific
4		4 drawer Filing	3	
5		1 Stationery Cup'd	1	
6		Coat hooks	3	

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	■
B2	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	■
B3	Doors (HBN 00-04)	Single Door	■ With Deadlock or digital lock
B4	Signage (HTM 65)		■
B5		Room Number sign	■
B6	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	■
B7	Noise (HTM (08-01)	Privacy	■ 40 (NR)
	SERVICES		
	Water (HTM 04-01)		
			N/R
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	■ environment to be 18-28°C
	Electrical (CIBSE design guide)		
E1	13A Double sockets E1 - Utility E1 - Desk E1 – Wall	Non-Essential Supply Low Level	2 No 2 No on dado trunking
	Gases (HTM 02-01)		
			N/A
	Lighting (EN12464-1)		
L1	General room lighting		Em = 300lx
L2	Emergency Lighting	Integral	
	Communication (HTM 08-03)		
C1	Data Outlet		1 No
C2	Fire Detection		1 No Smoke