

ROOM DATA SHEET				
Isolation Room		Date	Sept 2018	 Andrew Associates
		Room no.	R64	
		Rev. no	v1	
<i>This RDS is only a basic guideline of possible procurement items required for clinical & non-clinical rooms. Andrew Associates take no responsibility for individual hospital requirements and any inaccuracies associated with HTM/HBN standards.</i>				
FITTINGS				
Ref	Group	Item Description	Quantity	
1	1	Wash hand basin on IPS	1	- Complete with lever action sequential mixer bib tap - Basin to be clinical, no plug, no overflow, and back outlet, no tap holes
2	2	Paper Towel Dispenser (HBN 00-09)	1	
3	2	Soap Dispenser (HBN 00-09)	1	No soap dishes in healthcare environment
4	2	Hand Cream Dispenser (HBN 00-09)		
5	2	Hand Gel Dispenser (HBN 00-09)	1	Located outside the room and on the bed foot guard
6	2	PPE Dispenser	1	Outside the room
7	2	Sack holder (Clinical)	1	
8	2	Sack holder (domestic)	1	
9	3	Automatic medical bed	1	Low positioned 13amp power socket.
10	3	Patient Chair	1	
11	3	Visitor Chair	1	
12	3	Over bed table	1	
13	3	Suction Flowmeter	1	
14	3	Oxygen Flowmeter	1	
15	3	Air Flowmeter	1	
16	3	Drip Stand	1	As Required
17	3	IV pump	1	As Required
18	1	Bedhead Services system	1	Design specific.
19	3	Patient High back chair	1	

	BUILDING		Comment/ Quantity
Ref.			
B1	Walls	Low Odour Eggshell	
B2	Splashback		Whiterock or Similar
B3	Floors (HBN 00-10 Part A)	Homogeneous Vinyl or Rubber	Set-in coved skirting or coved skirting system - Design specific
B4	Doors (HBN 00-04)		Vision panel optional
B5	Signage (HTM 65)		
B6		Room Number sign	
B7	Ceilings (HBN 00-10 Part B)	BioGard™ Ceiling tiles	
B8	Noise (HTM (08-01)	Privacy	40 (NR)
B9	Observation window	Between glass blinds	Extn blind optional
	SERVICES		
	Water (HTM 04-01)		
W1	Hot water		1
W2	Cold water		1 Non potable -
	Ventilation, Heating, Cooling (HTM 03-01)		
V1	Heating/Ventilation	-ve (Extract) 6 AC/Hr	Environment to be 18-28°C Design specific
	Electrical (CIBSE design guide)		
E1	13A Double socket	Essential Supply	6 No per medical trunking
E2	13A Single socket	Non-Essential	1No low level per bed
E3	13A Wall socket	Non-Essential	As Required
	Gases (HTM 02-01)		
G1	Oxygen		1
G2	Suction		1
G3	Air		1
	Lighting (EN12464-1)		
L1	General room lighting	LED Modular	Em = 300lx
L2	Emergency Lighting	Integral	
L3	Examination Lamp	Luxo inspection lamps	1
L4	Overbed Lighting	Switched @ Trunking & NC handset	1 1
	Communication (HTM 08-03)		
C1	Data Outlet		As Required
C2	Fire Detection	Design specific	1 No Smoke